



Facility Name: Sebel Reef House & Spa

Facility Type: Hotel

Facility Address: 99 Williams Esplanade

**Phone: 07 4055 3633 – within Australia
+61 7 4055 3633 – International**

**Fax: 07 4055 3305 – within Australia
+61 7 4055 3305 – International**

Email: reservations@tsrhpc.mirvac.com

Web: www.reefhouse.com.au

Room numbers: one accessible room no interconnecting room

Recommended:

Recommended for ambulant and wheel chair users with a high level of function.



Parking:

There are no designated accessible parking bays. The Sebel staff will reserve a space if required in the undercover parking area downstairs as there is ample car parking spaces provided. Please advise when booking your room.

Entry into reception

Entry into reception is by way of a good wide accessible ramp located at the front. Reception is through a double manual door that leads into a level tiled area with ample seating.

The reception desk does not have a lowered section for wheel chairs but staff are very friendly and will assist where necessary.



Ramp leading to Main Reception



Reception

Entry into the hotels' restaurant is from the main ramp. There are no steps or lips into the restaurant making access very easy.

Access to public areas





No threshold into accessible room


Access onto the adjoining terrace level

Accommodation:

The accessible guest room is on the lower ground floor towards the back of the resort. There is level access into the room. The door handle is a knob style with a clear opening width of 750mm and has a very light opening force.

Room furniture can be moved to suit the guest's requirements, just notify staff when booking and they will be more than happy to assist.

The bed room has one double bed. The space beside the bed is 940mm at the widest spot. Under bed clearance is 130mm and the height to the top of mattress is 560mm.



Easy access from both sides of the bed.

There is a coffee/tea making facility and small bar fridge underneath. The TV can be controlled by remote from the bed. The height of the cupboard clothes rail is 1900mm above the floor.

Sanitary Facilities:

Entry into the accessible shower and toilet is through a 690mm clear opening door. The facility has a combined toilet and shower with a dimension of 2270mm long by 2350mm wide.



Note restricted access on front left side of toilet

Grab rails are fitted to the toilet wall and are mounted 810mm from the floor to top of grab rail.

The shower and toilet is in one large accessible area with no lips to catch caster wheels, although it has a wall and basin ledge protruding in front of the toilet with only 290mm gap between the edge of the closest wall and toilet, which would limit the left side access.

The height of the seat from floor is 410mm and 600mm to centre of pan from side wall.

There is a drop down shower seat provided.



Shower showing horizontal grab rail

Vertical grab rail and shower rose

Shower grab rails both vertical and horizontal are provided; the shower rose is on a sliding rail. The tap is a flick mix lever and easily accessible.



Clearance to the under side of the sink is 640mm with a height to top of sink at 760mm. The base of the mirror from floor is 1030mm.




Diagram not to scale.

General:

Staff are very friendly and will assist with baggage if required.

Assistance dogs are welcome on the premises.

The rooms are light and airy and in very good condition.

The hotel is located on the lovely Palm Cove Esplanade, which is accessible along the whole street.